

In order to prevent off-cycle siphoning of the pump it is recommended to install an air vent on the discharge piping when the outlet is below the collection reservoir. Doing so will increase the life expectancy of the pump and eliminate a lot of the excess noise of the pump.

